



7500 W 160th St., Stilwell, KS 66085 • (855) 714- FIRE (3473) • www.firedoorsolutions.com

Fire Damper Inspection Report

**Sample Hospital
Overland Park, KS**

**Inspection Dates:
4/24/2019 - 5/1/2019**

EC Code Reference

The hospital operates fire and smoke dampers one year after installation and then at least every six years to verify that they fully close. The results and completion dates are documented.

Note: For additional guidance on performing tests, see:

NFPA 90A-2012: 5.4.8

NFPA 80-2010: 19.4

NFPA 105-2010: 6.5

Fire Damper Inspections Report Summary

Inspection Summary

Total number of dampers inspected	9
Compliant dampers	8
Non-compliant dampers	1


Compliance Summary

Dampers not completely resolved	1
Dampers requiring client attention	0
Dampers requiring Phase 2	1


* Dampers can belong to more than one category above

30997007581 (S6-11)

PASS



Inspector: Joe Inspector Location: Restroom by visitor elevator B
 Inspection Date: 4/24/2019 5:19 PM Wall Type: Fire
 Building: North tower Type: Fire/Smoke Damper
 Floor: 6 Status: Life Safety




Deficiency Detail


Damper passed inspection

30997007582 (E606)

PASS



Inspector: Joe Inspector Location: 2nd bathroom by visitors elevator entrance B
 Inspection Date: 4/24/2019 5:32 PM Wall Type: Fire
 Building: North tower Type: Fire/Smoke Damper
 Floor: 6 Status: Life Safety




Deficiency Detail

Damper passed inspection

30997007583 (R609)

PASS



Inspector: Joe Inspector Location: Lobby of visitors lobby elevator entrance B by stairway
 Inspection Date: 4/24/2019 5:41 PM Wall Type: Fire
 Building: North tower Type: Fire/Smoke Damper
 Floor: 6 Status: Life Safety



Deficiency Detail



Damper passed inspection

30997007584 (FD6-021)

PASS



Inspector: Joe Inspector Location: Soiled utility across from visitors elevator A
 Inspection Date: 4/24/2019 6:15 PM Wall Type: Fire
 Building: North tower Type: Fire Damper
 Floor: 6 Status: Life Safety



Deficiency Detail



Damper passed inspection

30997007746

PASS



Inspector: Kyle Martinez Location: Medical equipment supply
 Inspection Date: 4/30/2019 5:09 PM Wall Type: Fire
 Building: North tower Type: Fire Damper
 Floor: 2 Status: Life Safety




Deficiency Detail

Damper passed inspection

30997007747

PASS



Inspector: Joe Inspector Location: Medical supply room
 Inspection Date: 4/30/2019 5:22 PM Wall Type: Fire
 Building: North tower Type: Fire Damper
 Floor: 2 Status: Life Safety



Deficiency Detail


Damper passed inspection

30997007748

NOT RESOLVED



Inspector: Joe Inspector Location: Corridor leading to nurses station
 Inspection Date: 4/30/2019 5:37 PM Wall Type: Fire
 Building: North tower Type: Fire/Smoke Damper
 Floor: 2 Status: Life Safety



Deficiency Detail


Could not be actuated due to missing test switch - NFPA 80-2010 19.4.7, NFPA 105-2010 6.5.9

Phase 1 Joe Inspector 4/30/2019 5:41 PM Deficiency not resolved: additional parts needed. Test switch needs installed





30997007845

PASS



Inspector:	Joe Inspector	Location:	POU room
Inspection Date:	5/1/2019 3:30 PM	Wall Type:	Fire
Building:	North tower	Type:	Fire Damper
Floor:	3	Status:	Life Safety



Deficiency Detail


Damper passed inspection

30997007846

PASS



Inspector:	Joe Inspector	Location:	Cardiac cath - supplies
Inspection Date:	5/1/2019 11:37 PM	Wall Type:	Fire
Building:	North tower	Type:	Fire Damper
Floor:	1	Status:	Life Safety



Deficiency Detail

Damper passed inspection

Inspection Report Certification

Prepared By:

Signed for and on behalf of Fire Door Solutions, LLC:

Joe Inspector

Joe Inspector

Life Safety Inspector
(855) 714-3473*Tommie Downs*

Tommie Downs

Executive Vice President of Operations

Customer Complaints or Appeals

Fire Door Solutions' Customers may file a complaint or appeal of inspection services rendered by emailing Tommie Downs, Executive Vice President of Operations at [tdowns@firedoorsolutions.com](mailto:t downs@firedoorsolutions.com). Please include specific details in regards to your complaint or appeal. Fire Door Solutions will respond to all complaints or appeals within 72 hours.

This report is for the exclusive use of Fire Door Solutions' (FDS) Client and is provided pursuant to the FDS Inspection Agreement between FDS and its Client. FDS' responsibility and liability are limited to the terms and conditions of the Inspection Agreement. FDS assumes no liability to any party, other than to the Client in accordance with the Inspection Agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the FDS name or one of its marks must first be approved in writing by FDS. This report in itself does not demonstrate that the material, product, or service is, or has ever been, eligible to bear a FDS registered mark. Inspections are not conducted for the purposes of production quality control and do not relieve the Client of their obligations in this respect. This report does not constitute certification. THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM FDS. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC ITEMS EVALUATED.

